

Cable cabinets
From KSE 300909 up to KSE 304509 with busbars.

Description:

Cable cabinets for distribution , cabinets mounted with Cu-busbars.
Class 2, IP 34D.

Electrical data:

Nominal voltage:	Un: 500 V
Rated impulse withst. Volt.	Uimp: 6 kV
Nominal current:	In : 630 Amp. 50 Hz.
Insulation level:	Ui : 1000 V
Utilization category :	IEC 439-1/5
Rated short-time withst. A	Icw.: 25 kA , 1 s
Rated peak withst. Current	Ipk: 52,5 kA
IP for busbar:	IP 20

Mechanical data:

Made of 2 mm sendzirmirgalvanized steel, roof made of 2 mm stainless steel. The corrosion properties have been improved by Rilsan coating.
Rilsan coating is used for the electrical isolation, classe 2.

Declaration of Conformity

TRIAX confirms that the product conforms to relevant EEC harmonised standards and consequently can carry the CE-mark.

Relevant harmonised standards:

EN 60439 – 1- 5.

This document is only valid with the signature of the person responsible for CE-marking by TRIAX .

Date: 01.01.2000

Signature. Ralf Anndersen , Triax A/S

TYPE:Cable cabinets with busbar.

Date/Sign. 01.01.2000
Page:1